

  
**INTER COUNTY**  
ENERGY COOPERATIVE

A Touchstone Energy Cooperative 

March 10, 2011

Mr. Reggie Chaney  
Director of Engineering  
Kentucky Public Service Commission  
P. O. Box 615  
Frankfort, KY 40602-0615

**RECEIVED**

MAR 15 2011

PUBLIC SERVICE  
COMMISSION


**Re: ADMINISTRATIVE CASE NO. 2006-00494 – AN INVESTIGATION OF  
THE RELIABILITY MEASURES OF KENTUCKY’S JURISDICTIONAL  
ELECTRIC DISTRIBUTION UTILITIES AND CERTAIN RELIABILITY  
MAINTENANCE PRACTICES**

Dear Mr. Chaney:

Enclosed is Inter-County Energy Cooperative’s Annual Report of Reliability pursuant to the Public Service Commission’s Order dated October 26, 2007 for Case No. 2006-00494.

If you have any further questions or comments, please direct those to Marvin Graham, Vice-President of Operations. His direct line is 859-936-7815 or email to [marvin@intercountyenergy.net](mailto:marvin@intercountyenergy.net).

Sincerely,



James L. Jacobus  
President/CEO



**INTER COUNTY**  
ENERGY COOPERATIVE

A Touchstone Energy Cooperative 

**Administrative  
Case No. 2006-00494**

**INTER-COUNTY ENERGY  
COOPERATIVE CORPORATION**  
P.O. Box 87 • Danville, KY 40423-0087  
Phone: (859) 236-4561 • Fax: (859) 236-3627

# **INTER-COUNTY ENERGY COOPERATIVE**

**Administrative Case No. 2006-00494**

## **CONTENT**

Electric Distribution Utility Annual Reliability Report

- Contact Information
- Report Year
- Major Event Days
- System Reliability Results
- Outage Cause Categories
- Worst Performing Circuits
- Vegetation Management Plan Review
- Utility Comments



# Electric Distribution Utility Annual Reliability Report

---

## SECTION 5: OUTAGE CAUSE CATEGORIES

Excluding MED

CAUSE CODE DESCRIPTION	SAIDI VALUE	CAUSE CODE DESCRIPTION	SAIFI VALUE
lightning 5.1.1	19.79	lightning 5.2.1	0.2520
equipment failure 5.1.2	17.44	rain, ice, snow, or free: 5.2.2	0.1289
rain, ice, snow, or free: 5.1.3	10.73	equipment failure 5.2.3	0.1168
trees cut into distributio 5.1.4	8.05	trees cut into distributic 5.2.4	0.0947
cars and trucks 5.1.5	7.24	cars and trucks 5.2.5	0.0562
high wind 5.1.6	5.58	high wind 5.2.6	0.0434
animals 5.1.7	2.80	deteriated installation 5.2.7	0.0346
trees 5.1.8	1.83	animals 5.2.8	0.0301
deteriated installation 5.1.9	1.40	caused by others 5.2.9	0.0222
caused by others 5.1.10	0.93	trees 5.2.10	0.0196

## SECTION 6: WORST PERFORMING CIRCUITS

CIRCUIT IDENTIFIER	SAIDI VALUE	MAJOR OUTAGE CATEGORY
Ottenham - Highland 6.1.1	514.74	Lightning
Howardstown - Sulpher Creek 6.1.2	511.68	High Wind
Hustonville - Peyton Store 6.1.3	320.34	Equipment failure
Crab Orchard - Gooch 6.1.4	189.30	Trees Cut Into Distribution
Spencer Hamilton - Loretto 6.1.5	163.50	Equipment failure
Waynesburg - Highland 6.1.6	163.32	Lightning
Dixville - H.T. Adams 6.1.7	161.64	Rain, Ice and Snow, and Freezing
Raywick - Sulpher Creek 6.1.8	153.00	Rain, Ice and Snow, and Freezing
WDKY - Toddville 6.1.9	143.58	Lightning
Ky Hwy 208 - Marion Industrial 6.1.10	136.68	Cars and Trucks

CIRCUIT IDENTIFIER	SAIFI VALUE	MAJOR OUTAGE CATEGORY
Ottenham - Highland 6.2.1	6.052	Lightning
Bourne - Toddville 6.2.2	3.313	Cars and Trucks
Howardstown - Sulpher Creek 6.2.3	2.834	High Wind
Crab Orchard - Gooch 6.2.4	2.589	Trees Cut Into Distrubution
Harrodsburg - H.T. Adams 6.2.5	2.041	Deteriorated Installation
Waynesburg - Gooch 6.2.6	1.907	Lightning
Raywick - Sulpher Creek 6.2.7	1.715	Rain, Ice and Snow, and Freezing
WDKY - Toodville 6.2.8	1.715	Lightning
Spencer Hamilton - Loretto 6.2.9	1.448	Equipment failure
Hustonville - Peyton Store 6.2.10	1.357	Equipment failure

---

# Electric Distribution Utility Annual Reliability Report

---

Additional pages may be attached as necessary

## SECTION 7: VEGETATION MANAGEMENT PLAN REVIEW

Inter-County Energy completed the third year of its 5 year vegetation management plan. Inter-County Energy is on schedule to complete its 5 year vegetation management plan within the 5 year plan period.

---

## SECTION 8: UTILITY COMMENTS

---

---